



CENTRAL POWER RESEARCH INSTITUTE

SWITCHGEAR TESTING & DEVELOPMENT STATION

GOVINDPURA, BHOPAL - 462 023, INDIA

Phone : + 91 (0) 755 586682 Fax : + 91 (0) 755 587774



NABL ACCREDITED
LABORATORY
Sheet 1 of 5

TEST REPORT

Test Report Number	S2030355	Date :
Name & address of the Client	Mutech Engineers 437/2, GIDC Makarpura Industrial Estate, Vadodara	
Name & address of the Manufacturer	Mutech Engineers 437/2, GIDC Makarpura Industrial Estate, Vadodara	
Particulars of sample tested	L.T Control Panel.	
Condition of sample on Receipt	New	
Type	PCC	
Designation	Nil	
Serial number	Nil	
Number of samples tested	One	
Date(s) of Test(s)	4 th June, 2003	
CPRI sample code no.	STDSST203S1600	
Particulars of tests conducted	Verification of the short circuit withstand strength	
Test in accordance with Standard/specification	IS:8623(Part1) - 1993, clause 8.2.3	
Sampling plan	Not applicable	
Client's requirement	Nil	
Deviations if any	Nil.	
Name of the Witnessing persons		
Client's representative	Shri. P.K.Geetey and Shri Dilip Soni	
Other than client's representatives	Nil	
Test subcontracted with address of the laboratory	None	
Documents constituting this report (in words)		
Number of sheets	Five	
Number of oscillograms	Two	
Number of graphs	Nil	
Number of photos	One	
Number of Test circuit diagrams	Two	
Number of drawings	Two	

(HIMANGSHU ROY)
TEST ENGINEER

(M.L.UNHALE)
JOINT DIRECTOR